



Government Of West Bengal
Office Of The Divisional Fire Officer, Murshidabad
West Bengal Fire & Emergency Services
C. R. Das Road, P.O.+P.S. :- Berhampur, Pin :- 742101

Memo no.:FSR/0125186220900187

Date: 16-12-2022

From:
Divisional Fire Officer, Murshidabad
West Bengal Fire & Emergency Services

To: Bhujanga Bhusan Ushangini B.Ed Institute
Over Plot - 07, 09, Kh No - 110, 443, Mouza - Faridpur, JL No - 64, at Vill - Ushagram, P.O Kuli-kandi, Ps-Burwan,
Dist-Murshidabad, W.B, Pin-742168

Sub: Fire Safety Certificate for a G+I storied Educational building named as "Bhujanga Bhusan Ushangini B.Ed. Institute" at Premises No- plot No.-07, 09 Kh.No.-110, 443; Mouza-Faridpur; J.L.No.-64, Vill.-Ushagram; P.O.-Kuli-Kandi; P.S.-Burwan, Dist-Murshidabad, Pin-742168.

This is in reference to your application no. 0125189220900094 dated 25-11-2022 regarding the Fire Safety Certificate for a G+I storied Educational building named as "Bhujanga Bhusan Ushangini B.Ed. Institute" at Premises No- plot No.-07, 09 Kh.No.-110, 443; Mouza-Faridpur; J.L.No.-64, Vill.-Ushagram; P.O.-Kuli-Kandi; P.S.-Burwan, Dist-Murshidabad, Pin-742168.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No parking will be allowed on the Drive way.
2. The Interior finish decoration of building shall be made with low flame spread material confirming I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any where and tear in them, particularly lines above false ceiling & ducts.
5. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable places of the building.

6.The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.

7.Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.

8.A trained Fireman shall be maintained round the clock for safety of the building.

9.First-Aid Fire Fighting system shall be provided as per I.S. Specification.

10.Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.

11.If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.

12.Periodical flashing of water from the Hydrants Pipe line shall be made to maintain the efficient working performance of above-mentioned system.

13.The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.

14.This Fire Safety Certificate is valid for three years and have to be renewed within stipulated period from the date of issue of this letter.

15.Any deviation and changes in the building in respect of the approved plan drawing, without obtaining prior permission from this office, this FSC will be treated as cancelled.

Divisional Fire Officer,Murshidabad
West Bengal Fire & Emergency Services